

Instructions: SST-150E/60E, Surface Mounted Transformer

Caution:

Turn off power at main service panel prior to installation.
For installation by a qualified electrician.
Read all instructions, and retain for future reference.

Track Mounted:

1. Secure the conduit adapter to the mounting plate with a hex nut.
2. Draw 120 volt wires to the transformer input wires, and connect using wire nuts.
3. Connect the supply side ground wire to the green grounding wire from the transformer base.
4. Secure the mounting plate to the mounting surface.
5. Secure the transformer output wires to a live end connector (see Powering Track Section).
6. Insert the live end connector into the track. Open the breakout on the cover and fit the live end connector against the cover. Finish by screwing the cover to the mounting plate.

Remote Mounted:

1. Secure the conduit adapter to the mounting plate with a hex nut.
2. Draw 120 volt wires to the transformer input wires and connect using wire nuts.
3. Connect the supply side ground wire to the green grounding wire from the transformer base.
4. Secure the mounting plate to the mounting surface.
5. Insert the strain relief bushing into the hole on the cover and secure with a hex nut from inside of the cover.
6. Connect transformer output wires to 12 gauge circuit wires, with wire nuts. Route the circuit wires through the strain relief bushing.
7. Tighten the set screw on the bushing to secure the outgoing circuit wires.
8. Finish by screwing the cover to the mounting plate.

